



METAL WINDOW CORPORATION

**Performance Testing**  
Structural, Air & Water

501 S. Isis Ave  
Inglewood, CA 90301  
310-665-0490 - Ph.  
310-641-7356 - Fax

	1500 Series	1500 Series	1500 Series	1500 Series	2000 Series	2000 Series	2000 Series	2000 Series	2000 Series	3000 Series	3500 Series	3500 Series	3500 Series	4000 Series	
	Casement Fixed Casement	Fixed Hopper Fixed	Fixed (O)	Fixed Awning Fixed	Casement Fixed Casement	Fixed Hopper Fixed	Fixed (O)	Fixed Awning Fixed	Single Casement	Standard Out-Swing Door	Sliding OX	Sliding OXO	Sliding OXXO	Sliding XXX	
Testing Facility	FTL	FTL	FTL	FTL	FTL	FTL	FTL	FTL	FTL	FTL	FTL	FTL	FTL	FTL	
Test Date	11/13/2006	11/16/2006	11/13/2006	11/16/2006	11/10/2006	11/9/2006	11/16/2006	11/9/2006	11/17/2006	11/17/2006	5/17/2004	2/24/2005	2/20/2005	10/17/2007	
Frame Size	102 X 64	52 X 104	64 X 64	52 X 104	116 X 64	64 X 108	62 X 74	64 X 108	36 X 66	48 X 96	95.50 X 95.75	141 X 96	192 X 96	180 X 120	
Panel Size(s)											44.50 X 94	48.43 X 93.25	47.25 X 93.50	48.62 X 93.50	60.98 X 118.50
Sash Size	33.37 X 62.12				34.75 X 61.75				34 X 64						
Hopper Size	50.25 X 33.50			61.75 X 33.25											
Awning Size	50.25 X 33.25			61.75 X 33.25											
Fixed Size	31.37 X 60.12	60.25 X 60.25		42 X 60	58 X 70				48.43 X 93.75		47.25 X 94	48.62 X 94			
Top Fixed Size	48.25 X 32.50			48.25 X 32.25			60 X 34.25								
Bottom Fixed Size	48.25 X 32.50			48.25 X 32.25			60 X 34.25								
Rating	C - C 50	AP - C 40	FW - C 60	AP - C 60	C - C 65	AP - C 40	FW - HC 70	AP - C 60	C - HC 50	SGD - C 40		SGD - C 40	SGD - C 35	SD - LC 25	
ASTM E 2068	•	•		•	•	•		•	•		•	•	•	•	
ASTM E 283	•	•	•	•	•	•	•	•	•	•	•	•	•	•	
ASTM E 547	•	•	•	•	•	•	•	•	•		•	•	•	•	
ASTM E 330	•	•	•	•	•	•	•	•	•	•	•	•	•	•	
ASTM E 331	•	•	•	•	•	•	•	•	•	•					
ASTM E 987											•	•	•	•	
ASTM F 588	•	•	•	•	•	•	•	•	•						
ASTM F 842														•	
CAWM 300-96											•	•	•		