



METAL WINDOW
CORPORATION

Performance Testing Thermal

501 S. Isis Ave
Inglewood, CA 90301
310-665-0490 - Ph.
310-641-7356 - Fax

	<i>1500 Series</i>	<i>1500 Series</i>	<i>2000 Series</i>	<i>2000 Series</i>	<i>3000 Series</i>	<i>3500 Series</i>	<i>4000 Series</i>
	Casement	Fixed	Casement	Fixed	Standard Out-Swing Single Door	Sliding OX	Sliding XXX
<i>Testing Facility</i>	AT	AT	AT	AT	AT	AT	AT
<i>Test Date</i>	10/14/2009	10/16/2009	10/13/2009	10/15/2009	10/16/2009	10/20/2009	10/21/2009
<i>Frame Size</i>	24 X 59	47 X 59	24 X 59	47 X 59	39 X 79	79 X 79	79 X 79
<i>Panel Size(s)</i>							
<i>Layer 1</i>	1/4" SB 60	1/4" SB 60	3/16" SB 60	1/4" SB 60	3/16" SB 60	3/16" SB 60	3/16" SB 60
<i>Gap</i>	AL Spacer (Argon Filled)	AL Spacer (Air Filled)	AL Spacer (Argon Filled)	AL Spacer (Air Filled)	AL Spacer (Argon Filled)	AL Spacer (Air Filled)	AL Spacer (Argon Filled)
<i>Layer 2</i>	1/4" Clear	1/4" Clear	3/16" Clear	1/4" Clear	3/16" Clear	3/16" Clear	3/16" Clear
<i>U-Factor</i>	0.56	0.43	0.61	0.44	0.61	0.52	0.53